


AMENDMENT OF SOLICITATION / MODIFICATION OF CONTRACT				1. Contract Number		Page of Pages 1 2	
2. Amendment/Modification Number DCKT-2011-B-0156-004		3. Effective Date See 16C Below		4. Requisition/Purchase Request No.		5. Solicitation Caption Installation of Storm Water Management System	
6. Issued by: Office of Contracting and Procurement Transportation and Specialty Equipment Commodity Group 2000 14 th Street, NW, 6 th Floor Washington, DC 20009				7. Administered by (If other than line 6) Department of Public Works Office of Administrative Services 2000 14 th Street, NW, 6 th Floor Washington, DC 20009			
8. Name and Address of Contractor (No. street, city, county, state and zip code) Code Facility				X		9A. Amendment of Solicitation DCKT-2011-B-0156	
						9B. Dated (See Item 11) 9/14/11	
						10A. Modification of Contract Order No.	
						10B. Dated (See Item 13)	
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<input type="checkbox"/> The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended. <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) BY separate letter or fax which includes a reference to the solicitation and amendment number. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such may be made by letter or fax, provided each letter or telegram makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. Accounting and Appropriation Data (If Required)							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14							
A. This change order is issued pursuant to (Specify Authority): The changes set forth in Item 14 are made in the contract/order no. in item 10A.							
B. The above numbered contract/order is modified to reflect the administrative changes (such as changes in paying office, appropriation data etc.) set forth in item 14, pursuant to the authority of 27 DCMR, Chapter 36, Section 3601.2.							
C. This supplemental agreement is entered into pursuant to authority of:							
D. Other (Specify type of modification and authority)							
E. IMPORTANT: Contractor <input type="checkbox"/> is not <input type="checkbox"/> is required to sign this document and return <u>1</u> copies to the issuing office.							
14. Description of Amendment/Modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible.) <div style="text-align: center; padding: 20px;">DCKT-2011-B-0156 is amended to provide the responses to additional bidder questions. See page 2.</div>							
Except as provided herein, all terms and conditions of the document referenced in item (9A or 10A) remain unchanged and in full force and effect.							
15A. Name and Title of Signer (Type or print)				16A. Name of Contracting Officer James Roberts			
15B. Name of Contractor <div style="text-align: center;">(Signature)</div>		15C. Date Signed		16B. District of Columbia  <div style="text-align: center;">(Signature of Contracting Officer)</div>		16C. Date Signed 10/19/2011	

AMENDMENT OF SOLICITATION / MODIFICATION OF CONTRACT			1. Contract Number	Page of Pages 2 2	
2. Amendment/Modification Number	3. Effective Date	4. Requisition/Purchase Request No.	5. Solicitation Caption		
DCKT-2011-B-0156-004	See 16C		Installation of Storm Water Management System		

RESPONSES TO BIDDERS QUESTIONS:

Q1. Most of the work occur in the parking lot and does not involve any mechanical system. Do we still have to conduct the procedural requirements 1, 2,3 mentioned in page 01790-1 Section 1.2 A?

A1. The contractor shall train DPW Staff on the operation and maintenance of all newly installed systems such as the new water fountain. The contractor shall conduct the training requirements in Section 01790.

Q2. Do we have to provide a full time project coordinator as mentioned in page 01040-2 Section 1.3 C?

A2. A project coordinator, "Manager" is required for this project. Whether or not he/she is full time or part time is left up to the contractor.

Q3. Specification calls for Windows 2007 operating system as mentioned on page 01320-7. Windows 2007 is very hard to find since it is almost obsolete. Can we use another operating system?

A3. You can use any software system for your CPM project scheduling as long as it is compatible with the latest windows operating system.

Q4. Temporary Facilities was mentioned on page 01500-2. Is this field office intended for DC DPW personnel or for the contractor?

A4. The field office at the site is for both DPW Engineers and Contractors' staff.

Q5. Section B of page 0110-1 mentioned the temporary use of Rehabilitation of Tire Shop located in 1827 West Virginia Avenue, NE. Is this still part of the scope of the project? Do we have to do any work on this tire shop?

A5. Delete all references to "Build Out of Tire Shop and Administrative Office " and insert in its place, "Installation of Storm Water Management Systems at Blue Plains".

Q6. Page 4 – Item B.5 of the above reference bid package indicates that if the contract is over \$250,000, 35% of the dollar volume of the contract shall be subcontracted in accordance with Section H. The Subcontracting Plan shall meet the requirements described under Section H of this solicitation. Section H.12.2 under Subcontracting Requirements indicates " A prime contractor which is certified as a small, local, disadvantaged business enterprise shall not be required to comply with the provisions of sections H.12.1.1 and H.12.1.2. Our question is, if we are a certified local business, do we have to comply with the 35% SBE set aside?

A6. As a Certified Local Business Enterprise (LBE), you are not required to subcontract 35% of the work. However the CBE prime contractor must self perform 35% of the contracting effort excluding the cost of materials, goods and supplies, with its own organization and resources and, if it subcontracts, at least 35% of the subcontracted effort, excluding the cost of materials, goods and supplies, shall be with certified business enterprises.

Q7. Water seals on the grate inlets are not shown in the detail drawings. Do we have to put any seal on these inlets?

A7. Yes

Q8. Invert elevations for SD27, SD26, SD33, SD34, SD42 and SD44 are missing on the plan. Can DDOT provide us this information?

A8. For Invert Elevations SD26, SD27,SD33, SD34 and SD44, please see Drawing C-3.2 and Storm Drain Profile Drawings C-3.16 and C-3.17.

Q9. Does DDOT have an approved supplier or manufacturer of Zee-Straps?

A9. No.